

**Combustion optimisation, efficiency improvements and emission reduction by installation of modern LowNO<sub>x</sub> firing systems at existing bituminous coal and lignite coal-fired steam generators**

Dr. Bernhard Zimmermann, Dr. Hans-Ulrich Thierbach, Niko Hachenberg, Karl Heinz Failing

## Energy products and solutions - in 6 divisions

Oil & Gas




Fossil  
Power  
Generation



Renewable  
Energy



Energy  
Service



Power  
Trans-  
mission



Power  
Distribution



**Energy Service Fossil  
Region Europe and Africa (REU)**

- **Efficiencies, price pressure, lower operation costs**
- **Meet requirements of European Emission Directive (especially recently EU joining countries)**
- **Operational flexibilities, e.g. extended load range and fuel properties (coal blends)**
- **Reduced time of full load operation and optimisation of part load conditions, frequent plant start up and shut down**
- **Increased load change rates (Primary and secondary frequency control), lifetime extension**

**Three examples of executed Firing projects within last two years:**


**2. Extension of Load Range**

**3. Flexibility improvement and reduced operating costs**

**4. Emission reduction and increase of availability**

## 2. Extension of load range

Main plant figures



### Once-through (Benson®) Type Boiler

Main steam flow 260 kg/s (936 t/h)

Temperature (SH/RH) 545 °C / 568 °C

Pressure (SH) 260 bar

Commissioning 1996

Mills for Bituminous Coal 6 Roller Mills

T-Firing, 12 SM-IV-Burner 61 MWth each

### Bituminous coal:

	Unit	Coal before revamp	Coal after revamp
NCV	MJ/kg	25,0 – 29,3	23,6 – 26,7
Water (ar)	w. %	5,5 – 13	7,4 – 16,2
Ash (ar)	w. %	7,0 – 20	4,7 – 15,5
VM (daf)	w. %	25 – 42	28 – 43

### Goal of retrofit:


- **Boiler capacity increase 10 %**
- **Keep NO<sub>x</sub>-Emissions ≤ 450 mg/Nm<sup>3</sup>**
- **Minimise slagging of furnace**
- **Corrosion protection of furnace walls (O<sub>2</sub>)**
- **Use of import coals**

### Measures:

- **Revamp to SM-V-Burner design (67 MWth)**
- **Modification of side wall air system**
- **Optimisation of OFA system**
- **Retrofit of mills**
- **Capacity increase of FD Fan**


## 2. Extension of load range

Firing concept



Over fire air


Side wall air



Secondary air 2

Secondary air 1

Primary fuel




## 2. Extension of load range

CFD calculation of furnace

Temperature  
profile  
with isosurface  
1500 °C

before revamp

Heat input 735 MW  
Air ratio 1,18



RECOM  
SERVICES

after revamp

Heat input 799 MW  
Air ratio 1,18


OFA

Burner level 3

Burner level 2

Burner level 1


improved position  
of fireball



RECOM  
SERVICES



Measured wall atmosphere **after revamp**



100 % > 1 % O<sub>2</sub>


	measured <b>before revamp</b>	CFD <b>after revamp</b>	measured <b>after revamp</b>
Load [%]	100	<b>109</b>	<b>109</b>
NO <sub>x</sub> [mg/Nm <sup>3</sup> @6%O <sub>2</sub> ]	304	<b>290</b>	<b>297 – 320</b>
CO [mg/Nm <sup>3</sup> @6%O <sub>2</sub> ]	26	<b>16</b>	<b>0 – 50</b>
FEGT [°C]	1236	<b>1265</b>	<b>1267</b>
UBC in fly ash [w. %]	1,7	<b>2,1</b>	<b>1,6 – 3,4</b>
O <sub>2</sub> < 0,5 [Vol. %]	1,6	<b>0,4</b>	<b>1,2</b>
Excess-Air-Ratio	1,18	<b>1,18</b>	<b>1,18</b>

## 2. Extension of load range

Life time experience

### SM-V-Ultra Low NO<sub>x</sub> Burner

after 8 years of operation - 03/2005



after 13 years of operation - 05/2010



**Three examples of executed Firing projects within last two years:**

**2. Extension of Load Range**

**3. Flexibility improvement and reduced operating costs**

**4. Emission reduction and increase of availability**


### 3. Flexibility improvement and reduced operating costs

Main plant figures

#### Benson type steam generator

**Fuel:** Bituminous Coal  
**Steam flow:** 420 kg/s / 1512 t/h  
**Temperature (SH/RH) :** 535 °C / 541°C  
**Pressure (SH):** 254 bar  
**Fuel heat input:** 1278 MWth  
**FEGT:** 1250 °C  
**Opposite firing system, 12 MSM-Burner, 100 MWth each**  
**Mills:** 3 Tube Mills  
**Commissioning:** 1989

	Unit	Ref. coal before revamp	Coal range after revamp
NCV	MJ/kg	25,1	16,7 – 26,4
Ash (a.r.)	Mass -%	7,1	6 – 30
Moisture (a.r.)	Mass -%	13,5	7 - 18
Volatiles (a.r.)	Mass -%	32,9	21 – 36,5



### Goal of retrofit:

- Simplification of firing system by removing the secondary fuel system (reburning)
- Extension of coal quality range (Import Coal with high volatile matter)
- Keep / Slight Reduction of primary NO<sub>x</sub> emissions
  - ⇒ Reduction of ammonia consumption
- Reduction of excess air ratio from 1,25 down to 1,18
  - ⇒ Reduction of flue gas losses and lower power consumption of fans
- Avoid furnace wall corrosion and slagging

### Measures:

#### 1. Firing system


- New burners
- Adding a new side wall air system
- Implementation of Over fire air

#### 2. Pulverising system (3 tube mills)

- Shut-off of secondary firing system (including flue gas recirculation system)
- Optimisation of PF distribution


### 3. Flexibility improvement and reduced operating costs

Combustion air system




### 3. Flexibility improvement and reduced operating costs

Burner design




„Uniform“ coal - air mixture





### 3. Flexibility improvement and reduced operating costs

Burner modification



### Burner modification



minimum hardware replacement  
and scope of work




### 3. Flexibility improvement and reduced operating costs

CFD calculation

#### O<sub>2</sub> concentration at furnace walls

before revamp ( $\lambda_{\text{tot}} = \lambda_{\text{BB}} = 1,25$ )

after revamp ( $\lambda_{\text{tot}} = 1,18, \lambda_{\text{BB}} < 1,0$ )




### 3. Flexibility improvement and reduced operating costs

CFD and measuring results

	measured <b>before revamp</b>	CFD <b>before revamp</b>	CFD No. 7 <b>after revamp</b>	measured <b>after revamp</b>
Coal	VM ~ 25% a.r.		Colombian coal	blend with low cont. of VM
FEGT [°C] (Mean / Maximum)	1211	<b>1215</b> <b>(1320)</b>	<b>1209</b> <b>(1312)</b>	~ 1225
Excess-Air-Ratio [-]	1,25	<b>1,25</b>	<b>1,18</b>	<b>1,18</b>
NO <sub>x</sub> [mg/Nm <sup>3</sup> , @ 6%O <sub>2</sub> ]	520 (±30)	<b>528</b>	<b>315</b>	<b>350 – 480</b>
CO [mg/Nm <sup>3</sup> , @ 6%O <sub>2</sub> ]	< 10	<b>15</b>	<b>8</b>	<b>&lt; 25</b>
UBC in Fly Ash [w. %]	ca. 3,2	<b>3,1</b>	<b>1,8</b>	~ 2,5

### 3. Flexibility improvement and reduced operating costs

Measuring results



**Three examples of executed Firing projects within last two years:**

**2. Extension of Load Range**

**3. Flexibility improvement and reduced operating costs**

**4. Emission reduction and increase of availability**

## 4. Emission reduction and increase of availability

Main plant figures

**Boiler type: Natural circulation**

**Fuel: Bulgarian lignite**

**Steam flow\*: 192 kg/s / 690 t/h**

**Temperature (SH/RH): 540 °C/ 540°C**

**Pressure (SH): 130 bar**

**Fuel heat input: 660 MWth**



**FGET: 1100 °C**

**Tangential firing, 8 mills**

**Commissioning 1981**

**\*Retrofit (8% load increase) 2009**

	Unit	Range
NCV (a.r.)	MJ/kg	6-7
Ash (a.r.)	w. %	10 – 20
Moisture (a.r.)	w. %	50 - 60
Volatiles (daf.)	w. %	~ 60



## 4. Emission reduction and increase of availability

### Goals and measures

#### Goals:


- Reduction of the NO<sub>x</sub> emissions from 375 to below 180 mg/Nm<sup>3</sup> @ 6% O<sub>2</sub>
- Increase of effectiveness of the combustion chamber by reduction the excess air from 1,2 to 1,15 (at furnace outlet)
- CO emissions below 180 mg/Nm<sup>3</sup> @ 6% O<sub>2</sub>
- Preventing water wall corrosion
- Decreasing slagging formation -> increase of availability

#### Measures:

- Burner outlet modification
  - Stabilise the ignition close to the burner outlet
  - Improve the release of volatiles
  - Optimisation of the furnace cross-section air distribution
  - Protect membrane walls against corrosion
- Modification of burner PF distribution
  - Staging the combustion more effective, reduce burner belt  
Excess Air Ratio
  - Influence the residence time inside the furnace

## 4. Emission reduction and increase of availability

New OFA system



Increase furnace burnout zone

Decrease loss of ignition


Equalise furnace outlet temperature

Create downstream mixing of flue gas



## 4. Emission reduction and increase of availability

Additional PF concentrator



% of PF distribution



Vapor burner



Upper main burner



Lower main burner





before / after

revamp

## 4. Emission reduction and increase of availability


Burner modification

Stable and early ignition,  
Preventing water wall corrosion



before  
revamp


after  
revamp



## 4. Emission reduction and increase of availability

Air / Coal mixture, Radial Air Staging


### Preventing water wall corrosion




## 4. Emission reduction and increase of availability

CFD calculation of combustion temperatures


Isosurface 1200 °C



before revamp



after revamp




## 4. Emission reduction and increase of availability

CFD calculation of furnace temperature

### Lower main burner

before revamp

after revamp




## 4. Emission reduction and increase of availability

CFD and measuring results

	measured <b>before revamp</b>	CFD <b>after revamp</b>	measured <b>after revamp</b>
Boiler efficiency	84		<b>84 + ~ 1,5</b>
NO <sub>x</sub> [mg/Nm <sup>3</sup> , @ 6%O <sub>2</sub> ]	350 - 400	<b>195</b>	<b>150 – 180</b>
CO [mg/Nm <sup>3</sup> , @ 6%O <sub>2</sub> ]	< 50	<b>270</b>	<b>30 - 100</b>
Excess-Air-Ratio at Boiler Outlet [-]	1,2	<b>1,2</b>	<b>1,1</b>
UBC hopper [%]	15	-	<b>~ 12</b>
UBC fly ash [%]	3	<b>4,8</b>	<b>~ 2,5</b>

## 4. Emission reduction and increase of availability

Measuring results



**The three presented retrofit projects show that the following goals were achieved:**

- **Load range extension**
- **Reduction of primary NO<sub>x</sub> emissions**
- **Cost reduction by improved efficiency and simplification**
- **Increase of operating flexibility**

**Thank you for your attention**